



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

August 16, 2012
Subject: **South Berwick**
State WIN: 019118.00
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: We are a manufacturer of Polymer Pipe, the only question we have is what is the Thickness of 603.023 Polymer Pipe?

Response: The culvert pipe must meet the requirements of the State of Maine, Department of Transportation, Standard Specifications, Revision of December 2002 including, but not limited to Section 603 - Pipe Culverts and Storm Drains, Subsections 603.02 - Materials and 603.03 - Construction Requirements, Section 700 - Materials, Subsection 707.07 - Polymer Precoated, Galvanized Corrugated Steel Pipe. The following sections from the Standard Specifications Revision of December 2002 are included for clarification:

707.07 Polymer Precoated, Galvanized Corrugated Steel Pipe and Pipe Arches This pipe and special fittings such as elbows, tees and wyes shall conform to the requirements of AASHTO M245/M245M, Grade 250/75 (Type I, with Type B coating) for the pipe as specified in AASHTO M246/M246M with the thinner coating on the outside.

Consider this information prior to submitting your bid on August 22, 2012.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER